

Digital Temperature Controller

FE400/700/800/900

FE250/251/300

Ver 1.6



Communication Manual



台灣儀控股份有限公司
TAIWAN INSTRUMENT & CONTROL CO., LTD

Contents

1.	Communication Specifications.....	1
2.	System Configuration	2
2.1	RS-485 Configuration	2
3.	Wiring	3
3.1	RS-485 Wiring	3
4.	Communication Parameter Setting	4
4.1	Setting Communication Parameter	4
4.2	Communication Parameter Functionality Outline	5
4.3	Procedure for Communication Parameter Setting	6
4.4	Master Communication Parameter Setting.....	9
5.	TAIE Protocol	11
5.1	Message Structure.....	11
5.2	Read A Register Format.....	12
5.3	Write A Register Format.....	12
5.4	Modify A Register Format.....	12
5.5	More Examples of Read/Write/Modify Example	13
5.5.1	Read a register.....	13
5.5.2	Write a register.....	13
5.5.3	Modify a register.....	14
6.	Modbus RTU Protocol	15
6.1	Message Structure.....	15
6.2	Read Register Format.....	16
6.2.1	Read a register format.....	16
6.2.2	Read multi register format.....	17
6.3	Write Register Format.....	17
6.3.1	Write a register format.....	17
6.3.2	Write multi register format	17
6.4	More Examples of Read/Write	18
6.4.1	Read a register.....	18
6.4.2	Read multi register	18
6.4.3	Write a register.....	19
6.4.4	Write multi register	19
6.4.5	Via communication read lamp and message	20
6.5	Error Code	22
6.5.1	Read Errors.....	22
6.5.2	Write Errors.....	22

6.5.3	Error command	23
6.6	EEPROM Protection Function.....	24
7.	Communication Parameters address.....	25
7.1	General Parameters Address.....	25
7.2	Piece Linear Compensation Parameters Address	37
7.3	All Model Parameters Address.....	38
7.3.1	RMAP = OFF	38
7.3.2	RMAP = FY.....	40
7.3.3	RMAP = FE.....	42

Copyright and Trademark

TAIWAN INSTRUMENT & CONTROL Co., Ltd. owns the copyright of this manual.

- Reproduction of this manual without express permission from
TAIWAN INSTRUMENT & CONTROL Co., Ltd. is prohibited.
- Modbus protocol is a communication protocol that Modicon Inc. Developed for PLC and Modbus
is a registered trademark of Schneider Electric.
- Other company names and the product names are the trademarks or registered trademarks of each
company.
- The On-line CRC calculation and free library is authorized by Mr. Lammert Bies

1. Communication Specifications

TAIE Protocol

Interface	RS-485
Baud rate	2400 bps, 4800 bps, 9600 bps, 19200 bps, 38400 bps, 57600 bps, 115200 bps
Data format	Parity bit : None, Odd, Even Data bit : 8 Stop bit : 1 or 2
Interval time	0~250ms
Function code	52H : Read 4DH : Modify 57H : Write
Error check	Sum of communication data, with Low Byte as error check.
MAX Number connections	Up to 31 units

MODBUS RTU Protocol




Interface	RS-485
Baud rate	2400 bps, 4800 bps, 9600 bps, 19200 bps, 38400 bps, 57600 bps, 115200 bps
Data format	Parity bit : None, Odd, Even Data bit : 8 Stop bit : 1 or 2
Interval time	0~250ms
Function code	03H : Read 06H : Write 10H : Multiple write
Error check	CRC-16
Error code	01H : Function code error 02H : Register address error 03H : Data count error
MAX Number connections	Up to 31 units

2. System Configuration

2.1 RS-485 Configuration

MAX number of connection unit for RS-485 communication interface is 31.


The spanning distance for controller connection PC Cable should not be more than 1200 meters.



3. Wiring


3.1 RS-485 Wiring

Use KA301 Converter to connect with controller



※ The spanning distance for controller connection PC Cable should not be more than 1200 meters.


Use IC485SN Converter connected to controller



※ The spanning distance for controller connection PC Cable should not be more than 1200 meters.

4. Communication Parameter Setting

4.1 Setting Communication Parameter




4.2 Communication Parameter Functionality Outline


Symbol	Content	Data Range		Initial
<i>P<small>PP</small>PP</i>	Communication Protocol	<i>0000</i> : Modbus RTU		<i>0000</i>
		<i>0001</i> : TAIE		
<i>E<small>EE</small>PR</i>	Data format	<i>0000</i>	None parity data bits =8 stop bit =1	<i>0000</i>
		<i>0001</i>	None parity data bits =8 stop bit =2	
		<i>0010</i>	Odd parity data bits =8 stop bit =1	
		<i>0011</i>	Odd parity data bits =8 stop bit =2	
		<i>0100</i>	Even parity data bits =8 stop bit =1	
		<i>0101</i>	Even parity data bits =8 stop bit =2	
		<i>0110</i>		
<i>0000</i>	ID Number	<i>00254</i>	: 0~254	<i>0000</i>
<i>0000</i>	Baud rate	<i>0004</i>	: 2400 bps	<i>0004</i>
		<i>0008</i>	: 4800 bps	
		<i>0016</i>	: 9600 bps	
		<i>0032</i>	: 19200 bps	
		<i>0064</i>	: 38400 bps	
		<i>0128</i>	: 57600 bps	
		<i>0256</i>	: 115200 bps	
<i>0000</i>	Response delay time	Response delay time(ms) When the controller receives command from master server, it will relay data back to master server in a delay of the set time value here.		<i>0000</i>
<i>0000</i>	Write mode	OFF :	As controller receives write-register command, it would only write to CPU RAM, not into EEPROM.	<i>0000</i>
		ON :	As controller receives write-register command, it would write to both CPU RAM and EEPROM, at the same time.	

4.3 Procedure for Communication Parameter Setting


1. Power ON & Initialization completed




2. Press SET key 3 seconds, will enter Level2.




3. Press SET key to search upper display showing the value indicated here. 8860




4. Set LOCK to 1000, press SET key + SHIFT key for 3 seconds to enter Level 5




5. Press SET key to search upper display showing the value indicated here. 8860




6. Press SHIFT key then lower display will start flash, press UP key or DOWN key to select communication protocol then pressing SET key to save the current setting.




7. Press SET key to search upper display showing the value indicated here.




8. Press SHIFT key then lower display will start flash, press UP key or DOWN key to select DATA format then pressing SET key to save the current setting.




9. Press SET key to search upper display showing the value indicated here.




10. Press SHIFT key then lower display will start flash, press UP key or DOWN key to select slave address then pressing SET key to save the current setting.





11. Press SET key to search upper display showing the value indicated here. 




12. Press SHIFT key then lower display will start flash, press UP key or DOWN key to select baud rate then pressing SET key to save the current setting.



13. Press SET key to search upper display showing value indicated here. 



14. Press SHIFT key then lower display will start flash, press UP key or DOWN key to select communication response delay time(ms) then pressing SET key to save the current setting.




4.4 Master Communication Parameter Setting


The host side needs to set the waiting time, timeout time, number of retries. Incorrect settings may cause abnormalities such as read errors and slow write responses. In order to obtain good communication quality, please refer to the following examples to set

Item	Name	Setting value	unit
1	Wait time	50	ms
	Response delay time		
	Delay time		
2	Timeout	1000	ms
3	Retry number	1	---

1. Connect via standard Modbus test software Modbus Poll



2. Connect via Mitsubishi PLC FX-3U



3. Connect via Pro-face HMI

Device/PLC 1

[Change Device/PLC](#)

Summary	Manufacturer: Modbus-IDA	Series: General MODBUS SIO Master	Port: COM1
Text Data Mode: 1	Change		
Communication Settings			
SIO Type	<input type="radio"/> RS232C	<input checked="" type="radio"/> RS422/485(2wire)	<input type="radio"/> RS422/485(4wire)
Speed	38400		
Data Length	<input type="radio"/> 7	<input checked="" type="radio"/> 8	
Parity	<input type="radio"/> NONE	<input type="radio"/> EVEN	<input checked="" type="radio"/> OBD
Stop Bit	<input checked="" type="radio"/> 1	<input type="radio"/> 2	
Flow Control	<input checked="" type="radio"/> NONE	<input type="radio"/> ER(DTR/CTS)	<input type="radio"/> XON/XOFF
Timeout	<input type="text" value="1"/> sec	Timeout	
Retry	<input type="text" value="1"/>	retry	
Wait To Send	<input type="text" value="50"/> ms	<input type="checkbox"/> Default Value	wait time
Mode	<input checked="" type="radio"/> RTU	<input type="radio"/> ASCII	
RI / VCC	<input checked="" type="radio"/> RI	<input type="radio"/> VCC	
In the case of RS232C, you can select the 9th pin to RI (Input) or VCC (5V Power Supply). If you use the Digital's RS232C Isolation Unit, please select it to VCC.			
Default			

5. TAIE Protocol

5.1 Message Structure

Function Code
ID number
Data
checksum

Function Code

Function Code	Command	Content
'R' (52H)	Read	Reading 1 register value from slave controller.
'M' (4DH)	Modify	Temporarily write 1 register value to controller's RAM. (When reboot the data will be lost)
'W' (57H)	Write	Write 1 register value to controller's RAM and EEPROM. (Data are maintained after power off)

Checksum

Add all the values from "Command" to the end of "Data". The result is Checksum (1 byte).

$$\boxed{\text{Command}} + \boxed{\text{ID}} + \boxed{\text{Data Address}} + \boxed{\text{Data}} = \boxed{\text{Checksum}} \rightarrow \boxed{\text{low byte}}$$

※ The Data response not include (Header)07H

EX (1) : Read the SV value of controller.

Command	Station	Register Address	Data	Add all	Checksum (get low byte)
('R') 52 H	+ 01 H	+ 0001H	+ 03E8 H	= 013F H	→ 3F H

EX (2) : Temporary write to SV value of controller.

Command	Station	Register Address	Data	Add all	Checksum (get low byte)
('M') 4D H	+ 01 H	+ 0001 H	+ 03E8 H	= 013A H	→ 3A H

EX (3) : Write to SV value of controller.

Command	Station	Register Address	Data	Add all	Checksum (get low byte)
('W') 57 H	+ 01 H	+ 0001 H	+ 03E8 H	= 0144 H	→ 44 H

5.2 Read A Register Format

Master send:

	No. of Byte	1	2	3	4	5	6	7
Master send	Command	52H('R')	01H	00H	00H	00H	00H	53H
	Comment	Read	ID Number	Register Address	Data		Checksum	

Controller response:

	No. of Byte	0	1	2	3	4	5	6	7
Controller response	Command	07H	4DH('M')	01H	00H	00H	03H	E8H	39H
	Comment	Header	Read	ID Number	Register Address	Data		Checksum	

5.3 Write A Register Format

Master send:

	No. of Byte	1	2	3	4	5	6	7
Master send	Command	57H('W')	01H	00H	01H	03H	E8H	44H
	Comment	Write	ID Number	Register Address	Data		Checksum	

Controller response:

	No. of Byte	1	2
Controller response	Command	4FH('O')	4BH('K')
	Comment	Message	

5.4 Modify A Register Format

Master send:

	No. of Byte	1	2	3	4	5	6	7
Master send	Command	4DH('M')	01H	00H	01H	00H	64H	B3H
	Comment	Modify	ID Number	Register Address	Data		Checksum	


Controller response:

	No. of Byte	1	2
Controller response	Command	4FH('O')	4BH('K')
	Comment	Message	


5.5 More Examples of Read/Write/Modify Example

5.5.1 Read a register

(1) Read P1, if P1=10.0




(2) Read AL1H, if AL1H =1234




5.5.2 Write a register

(1) Write AT =ON




(2) Write CYT1 =10




5.5.3 Modify a register

(1) Write SV =500



(2) Write R_S =RUN



6. Modbus RTU Protocol

6.1 Message Structure

ID Number
Function Code
Data
CRC-16 Modbus

ID number :

Controller station number in the RS-485 bus.

Function Code:

Command	Content
03 H	Read holding registers(max read parameter quantity:100)
06 H	Write single register
10 H	Write multiple registers(max write parameter quantity:8)

CRC-16 Modbus:

CRC-16 Modbus generation step are as below:

step 1 : CRC = FFFF(Hex) 2 Byte

step 2 : Calculate XOR with 1st data (start with n=1) and the low byte of CRC.

step 3 : If CRC data byte is 1

→ CRC = CRC >> 1;

CRC[^] = 0XA001;

or

→ CRC = CRC >> 1;

step 4 : Repeat step 3, do 8 times.

step 5 : Repeat step 2~4 finished the end of one.

step 6 : Reverse CRC's L/H(Byte), get CRD.

EX(1) Read to SV:

No. of Byte	1	2	3	4	5	6	7	8
Command	01 H	03 H	00 H	01 H	00 H	01 H	D5H	CAH
Comment	Station	Function Code	Register Address			Data Count	CRC-16 Modbus	

EX(2) Write to SV =1000:

No. of Byte	1	2	3	4	5	6	7	8
Command	01 H	06H	00 H	01 H	03 H	E8 H	D8 H	B4 H
Comment	Station	Function Code	Register Address			Data Count	CRC-16 Modbus	

EX(3) Write to AL1H =10, AL1L =5:

No. of Byte	1	2	3	4	5	6	7	8	9	10	11	12	13
Command	01 H	10 H	00 H	07H	00 H	02 H	04 H	00 H	0AH	00 H	05 H	52 H	48 H
Comment	Station	Function Code	Register Address		Data Count	Data Byte	Data 1		Data 2		CRC-16 Modbus		

CRC-16 refer to: <http://www.lammertbies.nl/comm/info/crc-calculation.html>

On-line CRC calculation and free library

- [Introduction on CRC calculations](#)
- [Free CRC calculation routines for download](#)
- [CRC calculation support forum](#) **New**

"010300000001" (hex)

1 byte checksum	5
CRC-16	0x1184
CRC-16 (Modbus)	0xA84
CRC-16 (Sick)	0x1108
CRC-CCITT (XModem)	0xBB53
CRC-CCITT (0xFFFF)	0xB543
CRC-CCITT (0x1D0F)	0x8A6D
CRC-CCITT (Kermit)	0x6E08
CRC-DNP	0x4C19
CRC-32	0x4A393840

010300000001 Calculate CRC
Input type: ASCII Hex

6.2 Read Register Format

6.2.1 Read a register format

Master send (Read SV):

Master send	No. of Byte	1	2	3	4	5	6	7	8
	Command	01H	03H	00H	01H	00H	01H	D5H	CAH
	Comment	ID Number	Command	Register Address		Data Count	CRC-16 Modbus		

Controller response (If SV = 100.0):

Controller response	No. of Byte	1	2	3	4	5	6	7
	Command	01H	03H	02H	03H	E8H	B8H	FAH
	Comment	ID Number	Command	Data Byte Count	Data	CRC-16 Modbus		

6.2.2 Read multi register format

FE controller can read up to 25 parameter information at a time, as user can choose the number of 1~25 for the number of data can be read at a time.

Master send (Read AL1H, AL1L):

Master send	No. of Byte	1	2	3	4	5	6	7	8
	Command	01H	03H	00H	07H	00H	02H	75H	CAH
	Comment	ID Number	Command	Register Address		Data Count	CRC-16 Modbus		

Controller response:

Controller response	No. of Byte	1	2	3	4	5	6	7	8	9
	Command	01H	03H	04H	00H	0AH	00H	05H	1AH	32H
	Comment	ID Number	Command	Data Byte Count	Data 1		Data 2	CRC-16 Modbus		

6.3 Write Register Format

6.3.1 Write a register format

Master send (Write SV =100):

Master send	No. of Byte	1	2	3	4	5	6	7	8
	Command	01H	06H	00H	01H	00H	64H	D9H	E1H
	Comment	ID Number	Command	Register Address		Data Count	CRC-16 Modbus		

Controller response:

Controller response	No. of Byte	1	2	3	4	5	6	7	8
	Command	01H	06H	00H	01H	00H	64H	D9H	E1H
	Comment	ID Number	Command	Register Address		Data Count	CRC-16 Modbus		

6.3.2 Write multi register format

FE controller can read up to 8 parameter information at a time, as users can choose the number of 1~8 for the number of data can be read at a time. in multi write mode approve master device write 8 registers once, user can setting 1~8 number in Data Count field.

Master send (Write AL1H =10, AL1L =5):

Master send	No. of Byte	1	2	3	4	5	6	7	8	9	10	11	12	13
	Command	01H	10H	00 H	07 H	00 H	02 H	04H	00 H	0A H	00 H	05 H	52H	48H
	Comment	ID Number	Command	Register Address		Data Count	Data Byte Count	Data 1		Data 2		CRC-16 Modbus		


Controller response:

	No. of Byte	1	2	3	4	5	6	7	8
Controller response	Command	01H	10H	00H	07H	00H	02H	F0H	09H
	Comment	ID Number	Command	Register Address	Data Count	CRC-16 Modbus			


6.4 More Examples of Read/Write

6.4.1 Read a register

(1) Read P1, If P1 =10.0




(2) Read AT, If AT =OFF




6.4.2 Read multi register

(1) Read AL1H, AL1L, AL2H,AL2L, If AL1H=10.0, AL1L=10.0, AL2H=5.0, AL2L=5.0




6.4.3 Write a register

(1) Write AT =ON




(2) Write CYT1 =10



6.4.4 Write multi register

(1) Continuous write AL1H, AL1L, AL2H, AL2L, If AL1H=10.0, AL1L=10.0, AL2H=5.0, AL2L=5.0



6.4.5 Via communication read lamp and message

MSG1 and LAP1 are 16-bit read-only parameters. Each bit has its indicated message or lamp. The lamp status and abnormal message can be read through communication.

Parameter	Content	Range		Address		R/W
		Max	Min	Hex	Dec	
MSG1	LOP1 error message indicator bit 2 ⁰ = INER 2 ¹ = UUUU 2 ² = NNNN 2 ³ = AUTF 2 ⁴ = r 2 ⁵ = r 2 ⁶ = r 2 ⁷ = r 2 ⁸ = CJER 2 ⁹ = CJOR 2 ¹⁰ = CJNR 2 ¹¹ = ADCF 2 ¹² = RAMF 2 ¹³ = r 2 ¹⁴ = r 2 ¹⁵ = r ※ r : reserve	65535	0	0x407	1031	R
LAP1	LOP1 led message indicator bit 2 ⁰ = OUT1 2 ¹ = OUT2 2 ² = AT 2 ³ = AL1 2 ⁴ = AL2 2 ⁵ = AL3 2 ⁶ = COM 2 ⁷ = MAN 2 ⁸ = Program_Run 2 ⁹ = Program_End 2 ¹⁰ = Program_Wait 2 ¹¹ = r 2 ¹² = Program_Halt 2 ¹³ = r 2 ¹⁴ = r 2 ¹⁵ = r ※ r : reserve	65535	0	0x408	1032	R

MSG1 data format

Bit 15	Bit 14	Bit 13	Bit 12	Bit 11	Bit 10	Bit 9	Bit 8	Bit 7	Bit 6	Bit 5	Bit 4	Bit 3	Bit 2	Bit 1	Bit 0
r	r	r	RAMF	ADCF	CJNR	CJOR	CJER	r	r	r	r	AUTF	NNNN	UUUU	INER
2 ¹⁵	2 ¹⁴	2 ¹³	2 ¹²	2 ¹¹	2 ¹⁰	2 ⁹	2 ⁸	2 ⁷	2 ⁶	2 ⁵	2 ⁴	2 ³	2 ²	2 ¹	2 ⁰
32768	16384	8192	4096	2048	1024	512	256	128	64	32	16	8	4	2	1

e.g. EEPROM failure, display RAMF error message
MSG1 read value→ 4096

e.g. input over range, display UUUU error message
MSG1 read value→ 2

LAP1 data format

Bit 15	Bit 14	Bit 13	Bit 12	Bit 11	Bit 10	Bit 9	Bit 8	Bit 7	Bit 6	Bit 5	Bit 4	Bit 3	Bit 2	Bit 1	Bit 0
r	r	r	P_H	r	P_W	P_E	P_R	MAN	COM	AL3	AL2	AL1	AT	OUT2	OUT1
2^{15}	2^{14}	2^{13}	2^{12}	2^{11}	2^{10}	2^9	2^8	2^7	2^6	2^5	2^4	2^3	2^2	2^1	2^0
32768	16384	8192	4096	2048	1024	512	256	128	64	32	16	8	4	2	1

e.g. OUT1,AL1,AL2,AL2 led lit on
 LAP1 read value → $1+8+16+32=57$

e.g. OUT1 led lit on and executing auto-tuning
 LAP1 read value → $1+4=5$

6.5 Error Code

Code	Content
(01H)	Illegal function code (Non-existent function code)
(02H)	Illegal register address (Register address is out of range)
(03H)	Illegal data count (Data count is out of setting range)

※ 1 is set to the MSB of function code in abnormal status.

6.5.1 Read Errors

(1) Register address is out of range

Master send:

Master send	No. of Byte	1	2	3	4	5	6	7	8
	Command	01H	03H	FFH	FFH	00H	01H	84H	2EH
	Comment	ID Number	Command	Register Address(error)		Data Count	CRC-16 Modbus		

Controller response:

Controller response	No. of Byte	1	2	3	6	7		
	Command	01H	83H	02H	C0H	F1H		
	Comment	ID Number	Command (MSB=1)	Error Code	CRC-16 Modbus			

(2) Data count is out of setting range

Master send:

Master send	No. of Byte	1	2	3	4	5	6	7	8
	Command	01H	03H	00H	00H	00H	1EH	C5H	C2H
	Comment	ID Number	Command	Register Address	Data Count (over range)		CRC-16 Modbus		

Controller response:

Controller response	No. of Byte	1	2	3	6	7		
	Command	01H	83H	03H	01H	31H		
	Comment	ID Number	Command (MSB=1)	Error Code	CRC-16 Modbus			

6.5.2 Write Errors

(1) Register address is out of range

Master send:

Master send	No. of Byte	1	2	3	4	5	6	7	8
	Command	01H	06H	FFH	FFH	00H	00H	89H	EEH
	Comment	ID Number	Command	Register Address(error)	Data		CRC-16 Modbus		

Controller response:

Controller response	No. of Byte	1	2	3	6	7
	Command	01H	86H	02H	C3H	A1H
	Comment	ID Number	Command (MSB=1)	Error Code	CRC-16 Modbus	

(2) Data count is out of setting range

Master send:

Master send	No. of Byte	1	2	3	4	5	6	7	8	9		
	Command	01H	10H	00H	02H	00	1A	12	00	64		
	Comment	ID Number	Command	Register Address	Data Count (over range)	Data Byte	Data 1				

Master send	No. of Byte		24	25	26	27						
	Command		00	64	C9	AC						
	Comment	...	Data 9		CRC-16 Modbus							

Controller response:

Controller response	No. of Byte	1	2	3	6	7
	Command	01H	90H	03H	0CH	01H
	Comment	ID Number	Command (MSB=1)	Error Code	CRC-16 Modbus	

6.5.3 Error command

(1) Non-existent function code

Master send

Master send	No. of Byte	1	2	3	4	5	6	7	8
	Command	01H	00H	00H	00H	00H	01H	C0H	0AH
	Comment	ID Number	Command (error)	Register Address	Data Count		CRC-16 Modbus		

Controller response:

Controller response	No. of Byte	1	2	3	6	7
	Command	01H	80H	01H	80H	00H
	Comment	ID Number	Command (MSB=1)	Error Code	CRC-16 Modbus	

6.6 EEPROM Protection Function

The memory system of the FE series controller is composed of EEPROM, and the number of times and years of memory of the EEPROM has its physical limitations, so a 24C16 EEPROM can be written to about 1 million times. The data retention is about 10 years. If the Master always send write command in high-speed communication, then the EEPROM has a high probability of being over-cycle in a short time, which means that the memory cell failure, the data can't be storage. To prevent this error, the FE series controller provides two protection modes, active protection and passive protection, please refer to the following description.

(1) Active Protection

The controller will automatically compare the data to be written, whether it is in Modbus RTU or TAIE protocol, when the received data is the same as the last received data, the controller will not write to EEPROM. The controller will only write to the EEPROM when it is different from the last received data.

EX : SV initial value =0, Master continue write to controller's SV

1. Master send SV =1000

FE EEPROM : will write to 1000

2. Master send SV =1000

FE EEPROM : No action

3. Master send SV =1000

FE EEPROM : No action

4. Master send SV =500

FE EEPROM : will write to 500

5. Master send SV =500

FE EEPROM : No action

6. Master send SV =500

FE EEPROM : No action

(2) Passive Protection

Set the parameter W_MD to OFF, when the controller receives the write command, it will only write data to the CPU RAM without writing data to the EEPROM. The advantage of this method is that you don't have to worry about write cycles of EEPROM, and the disadvantage is that the previously written data will not be storage after reboot.

EX1 : Set W_MD =OFF, SV initial =0, Master send SV =1000

Master send : 01H 06H 00H 01H 03H E8H D8H B4H

FE RAM (SV) =1000

FE EEPROM : No action

EX2 : Set W_MD =ON, SV initial =0, Master send SV =1000

Master send : 01H 06H 00H 01H 03H E8H D8H B4H

FE RAM (SV) =1000

FE EEPROM : write to 1000

※ This parameter (W_MD) can't be modify via communication, only available modify by the controller keypad.

7. Communication Parameters address

7.1 General Parameters Address

Parameter	Display	Level	Description	Range		Address				R/W	Initial		
				Max	Min	LOOP1		LOOP2					
						Hex	Dec	Hex	Dec				
PV		Level 1	Process value	USPL	LSPL	0x00	0	0x83	131	R	---		
SV		Level 1	Set value	USPL	LSPL	0x01	1	0x84	132	R/W	0		
LOOP		Level 1	Loop selection 0 : LOP1 (loop1) 1 : LOP2 (loop2)	1	0	0x02	2	0x85	133	R/W	0		
R_S		Level 1	RUN/STOP mode selection 0 : STOP (output & alarm disable) 1 : RUN (output & alarm enable)	1	0	0x03	3	0x86	134	R/W	0		
HBCU		Level 1	HBA current display unit : ampere(A)	---	---	0x04	4	0x87	135	R	---		
HBSV		Level 1	HBA current setting unit : ampere(A)	100.0	0.0	0x05	5	0x88	136	R/W	0		
HBTM		Level 1	HBA disconnection set time unit : second(S)	99.59	0	0x06	6	0x89	137	R/W	10		
AL1H		Level 1	Alarm1 upper set value (ALD1 = DE.HI / DE.HL / BA.ND / PR.HI / DEHI / DEHL / BAND / PRHI appear)	USPL	-1999	0x07	7	0x8A	138	R/W	10		
AL1L		Level 1	Alarm1 lower set value (ALD1 = DE.LO / DE.HL / BA.ND / PR.LO / DELO / DEHL / BAND / PRLO appear)	USPL	-1999	0x08	8	0x8B	139	R/W	10		
AL2H		Level 1	Alarm2 upper set value (ALD2 = DE.HI / DE.HL / BA.ND / PR.HI / DEHI / DEHL / BAND / PRHI appear)	USPL	-1999	0x09	9	0x8C	140	R/W	10		
AL2L		Level 1	Alarm2 lower set value (ALD2 = DE.LO / DE.HL / BA.ND / PR.LO / DELO / DEHL / BAND / PRLO appear)	USPL	-1999	0x0A	10	0x8D	141	R/W	10		
AL3H		Level 1	Alarm3 upper set value (ALD3 = DE.HI / DE.HL / BA.ND / PR.HI / DEHI / DEHL / BAND / PRHI appear)	USPL	-1999	0x0B	11	0x8E	142	R/W	10		
AL3L		Level 1	Alarm3 lower set value (ALD3 = DE.LO / DE.HL / BA.ND / PR.LO / DELO / DEHL / BAND / PRLO appear)	USPL	-1999	0x0C	12	0x8F	143	R/W	10		
SV1		Level 1	First set value (only available in DI function)	USPL	LSPL	0x0D	13	0x90	144	R/W	0		
SV2		Level 1	Second set value (only available in DI function)	USPL	LSPL	0x0E	14	0x91	145	R/W	0		
SV3		Level 1	Third set value (only available in DI function)	USPL	LSPL	0x0F	15	0x92	146	R/W	0		
SV4		Level 1	Fourth set value (only available in DI function)	USPL	LSPL	0x10	16	0x93	147	R/W	0		
TIM		Level 1	Timer PV address use for current time SV address use for target time (only available in DI function)	9959	0	0x11	17	0x94	148	R/W	0		
CNT		Level 1	Counter PV address use for current count SV address use for target count (only available in DI function)	9999	0	0x12	18	0x95	149	R/W	0		
CUTM		Level 1	24 hour timer Current time	2359	0	0x13	19	0x96	150	R/W	0		
ONTM		Level 1	24 hour timer, ON time PV address use for display current time SV address use for setting ON time	2359	0	0x14	20	0x97	151	R/W	0		

7. Communication Data List

Parameter	Display	Level	Description	Range		Address				R/W	Initial		
				Max	Min	LOOP1		LOOP2					
						Hex	Dec	Hex	Dec				
OFTM		Level 1	24 hour timer, OFF time PV address use for display current time SV address use for setting OFF time	2359	0	0x15	21	0x98	152	R/W	0		
A_M		Level 1	Auto/Manual mode switch 0 : AUTO (auto mode) 1 : MMAN (main output manual mode) 2 : SMAN (sub output manual mode)	2	0	0x16	22	0x99	153	R/W	0		
MOUT		Level 1	Manual manipulated output setting value	100.0	0.0	0x17	23	0x9A	154	R/W	0		
AT		Level 1	Auto-tuning execute selection 0 : OFF (PID control) 1 : ON (execute auto tuning)	1	0	0x18	24	0x9B	155	R/W	0		
RATE		Level 1	Slave SV rate RATE SV = SV x (RATE/9999)	9999	0	0x19	25	0x9C	156	R/W	9999		
RAMP		Level 1	The rate of change during SV ramp operation format : °C / minute	99.99	-19.99	0x1A	26	0x9D	157	R/W	0		
SOAK		Level 1	Soak time Time format : min.sec	9959	0	0x1B	27	0x9E	158	R/W	0		
WAIT		Level 1	Program execution standby temperature 0 : when program execute do not wait for PV temperature Other values : when PV= (target SV-WAIT) program entering next segment	1000	0	0x1C	28	0x9F	159	R/W	0		
DTM1		Level 1	Reserve	9959	0	0x1D	29	0xA0	160	R/W	0		
DTM2		Level 1	Reserve	9959	0	0x1E	30	0xA1	161	R/W	0		
DTM3		Level 1	Reserve	9959	0	0x1F	31	0xA2	162	R/W	0		
DTM4		Level 1	Reserve	9959	0	0x20	32	0xA3	163	R/W	0		
DT.ST		Level 1	Reserve	9959	0	0x21	33	0xA4	164	R/W	0		
PTN		Level 1	Program pattern selection 1~15	15	0	0x22	34	0xA5	165	R	0		
SEG		Level 1	Program segment selection 1~10	150	1	0x23	35	0xA6	166	R	1		
L1SV		Level 1	LOOP1 current segment target SV	USPL	LSPL	0x24	36	0xA7	167	R	0		
L2SV		Level 1	LOOP2 current segment target SV	USPL	LSPL	0x25	37	0xA8	168	R	0		
TIMR		Level 1	Current segment execute time setting, this parameter determines the link between segment and segment or pattern and pattern END(-1) : program end in this segment 00.00 : program step change in this segment 00.01~99.58 : program in this segment execute time COTI(99.59) : program continue execute this segment no end	9959	-1	0x26	38	0xA9	169	R	0		
MOLH		Level 1	Current segment output limit	1000	0	0x27	39	0xAA	170	R/W	1000		

Parameter	Display	Level	Description	Range		Address				R/W	Initial		
				Max	Min	LOOP1		LOOP2					
						Hex	Dec	Hex	Dec				
P1		Level 2	Main output proportional band 0 : ON/OFF control Other values : proportional band setting value	200.0	0.0	0x28	40	0xAB	171	R/W	3.0		
I1		Level 2	Main output integral time 0 : disable integral function Other values : integral time setting value	3600	0	0x2A	42	0xAD	173	R/W	240		
D1		Level 2	Main output derivative time 0 : disable derivative function Other values : derivative time setting value	900	0	0x2C	44	0xAF	175	R/W	60		
HYS1		Level 2	Hysteresis for main output on/off control use(when P1 = 0.0 appear) heating formula : PV ≥ (SV + HYS1) → OUT1=OFF PV ≤ (SV - HYS1) → OUT1=ON cooling formula : PV ≥ (SV + HYS1) → OUT1=ON PV ≤ (SV - HYS1) → OUT1=OFF	1000	-1000	0x2E	46	0xB1	177	R/W	10		
CYT1		Level 2	Main output control cycle 0 : Linear signal 1 : SSR drive 2~150 : Relay	150	0	0x2F	47	0xB2	178	R/W	10		
MOLH		Level 2	High limit setting of manipulated value for main output	100.0	0.0	0x30	48	0xB3	179	R/W	100.0		
MOLL		Level 2	Low limit setting of manipulated value for main output	100.0	0.0	0x31	49	0xB4	180	R/W	0.0		
P2		Level 2	Sub output proportional band 0 : ON/OFF control Other values : proportional band setting value	200.0	0.0	0x32	50	0xB5	181	R/W	3.0		
I2		Level 2	Sub output integral time 0 : disable integral function Other values : integral time setting value	3600	0	0x34	52	0xB7	183	R/W	240		
D2		Level 2	Sub output derivative time 0 : disable derivative function Other values : derivative time setting value	900	0	0x36	54	0xB9	185	R/W	60		
HYS2		Level 2	Hysteresis for sub output on/off control(when P2 = 0.0 appear)	1000	-1000	0x38	56	0xBB	187	R/W	10		
CYT2		Level 2	Sub output control cycle 0 : Linear signal 1 : SSR drive 2~150 : Relay	150	0	0x39	57	0xBC	188	R/W	10		
SOLH		Level 2	High limit setting of manipulated value for sub output.	100.0	0.0	0x3A	58	0xBD	189	R/W	100.0		
SOLL		Level 2	Low limit setting of manipulated value for sub output.	100.0	0.0	0x3B	59	0xBE	190	R/W	0.0		
MGAP		Level 2	Control gap (for main output)	1000	-1000	0x3C	60	0xBF	191	R/W	0		
SGAP		Level 2	Control gap (for sub output)	1000	-1000	0x3D	61	0xC0	192	R/W	0		
COUT		Level 2	Current manipulated output value	100.0	0.0	0x3E	62	0xC1	193	R	0.0		
AT.VL		Level 2	Auto-tuning offset value execute auto-tuning in (SV+ATVL) point	1000	-1000	0x3F	63	0xC2	194	R/W	0		
SS.PO		Level 2	If SETF.2=0, in manual mode or error condition controller will load this setting value as manipulated value.	100.0	0.0	0x40	64	0xC3	195	R/W	50.0		

7. Communication Data List

Parameter	Display	Level	Description	Range		Address				R/W	Initial		
				Max	Min	LOOP1		LOOP2					
						Hex	Dec	Hex	Dec				
OPSF		Level 2	Main output special function selection 0 : NONE (special function OFF) 1 : SQUA (manipulated output value square) 2 : ROOT (manipulated output value square root) 3 : REVE (manipulated output value reverse) 4 : SQ.RE (manipulated output value square reverse) 5 : RO.RE (manipulated output value square root reverse)	5	0	0x41	65	0xC4	196	R/W	0		
RC.TO		Level 2	Output filter Unit : second	10.00	1.00	0x42	66	0xC5	197	R/W	2.00		
LOCK		Level 2	Function/level lock 0000 = 0 0001 = 1 0010 = 16 0011 = 17 0100 = 256 0101 = 257 0110 = 272 0111 = 273 1000 = 4096 1001 = 4097 1010 = 4112 1011 = 4113 1100 = 4352 1101 = 4353 1110 = 4368 1111 = 4369	4369	0	0x43	67	0xC6	198	R/W	0		
INPT		Level 3	Input type selection 0 : K1 (-50.0~600.0°C) 1 : K2 (-50~1200°C) 2 : J1 (-50.0~400.0°C) 3 : J2 (-50~400°C) 4 : R (-50~1760°C) 5 : S (-50~1760°C) 6 : B (-50~1820°C) 7 : E (-50~900°C) 8 : N (-50~1300°C) 9 : T1 (-199.9~400.0°C) 10 : T2 (-199~400°C) 11 : W (-50~2320°C) 12 : PL (-50~1200°C) 13 : L (-50~800°C) 14 : PT1 (-199.9~850.0°C) 15 : PT2 (-199~850°C) 16 : PT3 (0~850°C) 17 : AN1 18 : AN2 19 : AN3 20 : AN4	22	0	0x44	68	0xC7	199	R/W	17		
AN.LO		Level 3	Analog input zero calibration, only available in linear input	9999	-1999	0x45	69	0xC8	200	R/W	0		
AN.HI		Level 3	Analog input span calibration, only available in linear input, hex display	0x7FFF	0x0000	0x46	70	0xC9	201	R/W	0x5FFF		
DP		Level 3	Decimal point position (only available in linear signal input) 0 : 0000 1 : 000.0 2 : 00.00 3 : 0.000	3	0	0x47	71	0xCA	202	R/W	0		

Parameter	Display	Level	Description	Range		Address				R/W	Initial		
				Max	Min	LOOP1		LOOP2					
						Hex	Dec	Hex	Dec				
HI.RA	HI.RA	Level 3	Input scale high(for analog input)	9999	-1999	0x48	72	0xCB	203	R/W	---		
LO.RA	LO.RA	Level 3	Input scale low(for analog input)	9999	-1999	0x49	73	0xCC	204	R/W	---		
USPL	USPL	Level 3	Input scale high(for Thermocouple or RTD)	9999	-1999	0x4A	74	0xCD	205	R/W	---		
LSPL	LSPL	Level 3	Input scale low(for Thermocouple or RTD)	9999	-1999	0x4B	75	0xCE	206	R/W	---		
ALD1	ALD1	Level 3	Alarm1 mode selection 0 : NONE 1 : DE.HI 2 : DE.LO 3 : DE.HL 4 : BA.ND 5 : PR.HI 6 : PR.LO 7 : PEND 8 : SYAB 9 : HBA 10 : MSOK 11 : DEHI 12 : DELO 13 : DEHL 14 : BAND 15 : PRHI 16 : PRLO 17 : PRUN 18 : SYNO 19 : SOAK 20 : TIM 21 : CNT 22 : CUTM 23 : FSOK 24 : SEG	24	0	0x4C	76	0xCF	207	R/W	11		
ALT1	ALT1	Level 3	FLIK (00.00) : Flicker COTI (99.59) : Continued ON 00.01~99.58 : delay time	9959	0	0x4D	77	0xD0	208	R/W	9959		
HYA1	HYA1	Level 3	Hysteresis setting for alarm1	9999	-1999	0x4E	78	0xD1	209	R/W	0		
SEA1	SEA1	Level 3	Alarm1 special function setting 0000 = 0 0001 = 1 0010 = 16 0011 = 17 0100 = 256 0101 = 257 0110 = 272 0111 = 273 1000 = 4096 1001 = 4097 1010 = 4112 1011 = 4113 1100 = 4352 1101 = 4353 1110 = 4368 1111 = 4369	4369	0	0x4F	79	0xD2	210	R/W	0		
ALD2	ALD2	Level 3	Alarm2 mode selection (refer to ALD1)	24	0	0x50	80	0xD3	211	R/W	11		
ALT2	ALT2	Level 3	FLIK (00.00) : Flicker COTI (99.59) : Continued ON 00.01~99.58 : delay time	9959	0	0x51	81	0xD4	212	R/W	9959		
HYA2	HYA2	Level 3	Hysteresis setting for alarm2	9999	-1999	0x52	82	0xD5	213	R/W	0		
SEA2	SEA2	Level 3	Alarm2 special function setting	4369	0	0x53	83	0xD6	214	R/W	0		
ALD3	ALD3	Level 3	Alarm1 mode selection (refer to ALD1)	24	0	0x54	84	0xD7	215	R/W	11		
ALT3	ALT3	Level 3	FLIK (00.00) : Flicker COTI (99.59) : Continued ON 00.01~99.58 : delay time	9959	0	0x55	85	0xD8	216	R/W	9959		

7. Communication Data List

Parameter	Display	Level	Description	Range		Address				R/W	Initial		
				Max	Min	LOOP1		LOOP2					
						Hex	Dec	Hex	Dec				
HYA3	H3H3	Level 3	Hysteresis setting for alarm3	9999	-1999	0x56	86	0xD9	217	R/W	0		
SEA3	SCH3	Level 3	Alarm1 special function setting	4369	0	0x57	87	0xDA	218	R/W	0		
MOCL	DOOL	Level 3	Main output zero calibration only available for linear signal	9999	0	0x58	88	0xDB	219	R/W	0		
MOCH	DOLH	Level 3	Main output span calibration only available for linear signal	9999	0	0x59	89	0xDC	220	R/W	3600		
SOCL	SOOL	Level 3	Sub output zero calibration only available for linear signal	9999	0	0x5A	90	0xDD	221	R/W	0		
SOCH	SOLH	Level 3	Sub output zero calibration only available for linear signal	9999	0	0x5B	91	0xDE	222	R/W	3600		
MV.SF	DOLC	Level 3	Analog input special function selection 0 : NONE (special function OFF) 1 : SQUA (analog input square) 2 : ROOT (analog input square root) 3 : REVE (analog input reverse) 4 : SQ.RE (analog input square reverse) 5 : RO.RE (analog input square root reverse)	5	0	0x5C	92	0xDF	223	R/W	0		
RC.TI	PLD	Level 3	Input digital filter Unit : second	10.00	0.01	0x5D	93	0xE0	224	R/W	2.00		
UNIT	UUD	Level 3	Unit 0 : °C 1 : °F 2 : U (Linear signal)	2	0	0x5E	94	0xE1	225	R/W	---		
OUTM	DUO	Level 3	Control action selection 0 : HEAT (reverse action) 1 : COOL (direct action)	1	0	0x5F	95	0xE2	226	R/W	0		
SV.OS	SUDS	Level 3	SV bias	1000	-1000	0x60	96	0xE3	227	R/W	0		
PV.OS	PUDS	Level 3	PV bias(for zero) PV = PV x (PV.OH / 5000) + PV.OS	1999	-1999	0x61	97	0xE4	228	R/W	0		
PV.OH	PUDH	Level 3	PV bias(for span) PV = PV x (PV.OH / 5000) + PV.OS	9999	0	0x62	98	0xE5	229	R/W	5000		
MLNB	DUDH	Level 3	Piece linear compensation segment select TRIP : leave setting loop 1~10 : segment select	10	0	0x63	99	0xE6	230	R/W	0		
COMP	UDU	Level 3	Piece linear compensation compare value	USPL	LSPL	0x64	100	0xE7	231	R/W	0		
OFFS	OFFS	Level 3	Piece linear compensation offset value	1500	-1500	0x65	101	0xE8	232	R/W	0		
SV.TY	SULT	Level 4	SV source selection LOOP1 0 : FIX (local SV) 1 : RATE (uart data x RATE/9999) 2 : RAMP (ramp SV) 3 : CASC (cascade control) 4 : ANAG (remote SV) 5 : ANRA (remote SV x RATE/9999) 6 : PROG (program SV)	6	0	0x66	102	0xE9	233	R/W	0		
			LOOP2 0 : FIX (local SV) 1 : RATE (uart data x RATE/9999) 2 : RAMP (ramp SV) 3 : CASC (cascade control)										

Parameter	Display	Level	Description	Range		Address				R/W	Initial		
				Max	Min	LOOP1		LOOP2					
						Hex	Dec	Hex	Dec				
OU.TY		Level 4	Hardware drive selection LOOP1 0 : SING (single output) 1 : DOUB (dual output) 2 : 1SCR (single phase control) 3 : HLSL (high low signal selection) 4 : FBMV (valve control with feedback) 5 : NFMV (valve control without feedback) LOOP2 0 : SING (single output) 1 : DOUB (dual output) 2 : 1SCR (single phase control) 3 : HLSL (high low signal selection) 4 : NFMV (valve control without feedback)	5	0	0x67	103	0xEA	234	R/W	0		
PMAC		Level 4	Automatic valve position adjustment 0 : OFF stop automatic adjust 1 : ON start automatic adjust 2 : E_PB Valve position determined by external button	2	0	0x68	104	0xEB	235	R/W	0		
FKSL		Level 4	A/M key function mode selection 0 : OFF (disable A/M key) 1 : R_S (switch RUN/STOP) 2 : A_M (switch auto/manual) 3 : AT (ON/OFF auto-tuning) 4 : LOOP (switch LOOP1/2)	1	0	0x69	105	0xEC	236	R/W	0		
BIAS		Level 4	Reserve	1000	-1000	0x6A	106	0xED	237	R/W	0		
TP_K		Level 4	Reserve	1000	10	0x6B	107	0xEE	238	R/W	150		
TMSL		Level 4	24 hour timer, mode selection 0 : OFF (24 hour timer function disable) 1 : SWSV (switch SV) 2 : R_S (switch RUN/STOP) 3 : R_SO (switch to run)	3	0	0x6C	108	0xEF	239	R/W	0		
MVRT		Level 4	Motor valve traveling time Time unit : second	150	5	0x6D	109	0xF0	240	R/W	45		
HYSM		Level 4	Motor valve action main adjustment unit : percentage	5.0	0.0	0x6E	110	0xF1	241	R/W	1.0		
RH.TC		Level 4	Dehumidification temperature If PV less than RHTC manipulated value = RHP0	2000	0	0x6F	111	0xF2	242	R/W	1250		
RH.PO		Level 4	Dehumidification manipulated value 0 : OFF disable dehumidification function Other values : 0.1~100.0 manipulated value	1000	0	0x70	112	0xF3	243	R/W	0		
RH.TM		Level 4	Dehumidification time time format : min.sec	9959	0	0x71	113	0xF4	244	R/W	1500		
PR.SV		Level 4	Reserve	USPL	LSPL	0x72	114	0xF5	245	R/W	100.0		
HBOP		Level 4	Output percentage of trigger HBA	100.0	0.0	0x73	115	0xF6	246	R/W	90.0		
SET1		Level 4	Parameter Hide/Display	4369	0	0x74	116	0xF7	247	R/W	---		
SET2		Level 4	Parameter Hide/Display	4369	0	0x75	117	0xF8	248	R/W	---		
SET3		Level 4	Parameter Hide/Display	4369	0	0x76	118	0xF9	249	R/W	---		
SET4		Level 4	Parameter Hide/Display	4369	0	0x77	119	0xFA	250	R/W	---		
SET5		Level 4	Parameter Hide/Display	4369	0	0x78	120	0xFB	251	R/W	---		
SET6		Level 4	Parameter Hide/Display	4369	0	0x79	121	0xFC	252	R/W	---		
SET7		Level 4	Parameter Hide/Display	4369	0	0x7A	122	0xFD	253	R/W	---		

7. Communication Data List

Parameter	Display	Level	Description	Range		Address				R/W	Initial		
				Max	Min	LOOP1		LOOP2					
						Hex	Dec	Hex	Dec				
SET8	SE8	Level 4	Parameter Hide/Display	4369	0	0x7B	123	0xFE	254	R/W	---		
SET9	SE9	Level 4	Parameter Hide/Display	4369	0	0x7C	124	0xFF	255	R/W	---		
SETA	SEA	Level 4	Parameter Hide/Display	4369	0	0x7D	125	0x100	256	R/W	---		
SETB	SEB	Level 4	Parameter Hide/Display	4369	0	0x7E	126	0x101	257	R/W	---		
SETC	SEC	Level 4	Parameter Hide/Display	4369	0	0x7F	127	0x102	258	R/W	---		
SETD	SED	Level 4	Parameter Hide/Display	4369	0	0x80	128	0x103	259	R/W	---		
SETE	SEE	Level 4	Parameter Hide/Display	4369	0	0x81	129	0x104	260	R/W	---		
SETF	SEF	Level 4	Parameter Hide/Display	4369	0	0x82	130	0x105	261	R/W	---		
HZ	HZ	Level 5	Power frequency 0 : 50HZ 1 : 60HZ	1	0	0x106	262	0x106	262	R/W	1		
PRTO	PRO	Level 5	Protocol selection 0 : TAIIE 1 : MRTU	1	0	0x107	263	0x107	263	R/W	1		
FOMA	FOMA	Level 5	Data format 0 : O_81 (parity bit=odd, stop bit=1) 1 : O_82 (parity bit=odd, stop bit=2) 2 : E_81 (parity bit=even, stop bit=1) 3 : E_82 (parity bit=even, stop bit=2) 4 : N_81 (parity bit=none, stop bit=1) 5 : N_82 (parity bit=none, stop bit=2)	5	0	0x108	264	0x108	264	R/W	0		
IDNO	IDNO	Level 5	Controller address	255	0	0x109	265	0x109	265	R/W	1		
BAUD	BAUD	Level 5	Baud rate 0 : 24(2400) 1 : 48(4800) 2 : 96(9600) 3 : 192(19200) 4 : 384(38400) 5 : 576(57600) 6 : 1152(115200) bps	6	0	0x10A	266	0x10A	266	R/W	4		
RPDT	RPDT	Level 5	Response delay time(ms) When controller receive master command will delay this setting value then response master	250	0	0x10B	267	0x10B	267	R/W	0		
AOEN	AOEN	Level 5	Retransmission function enable 0 : OFF (Disable) 1 : ON (Enable)	1	0	0x10C	268	0x10C	268	R/W	0		
AOSL	AOSL	Level 5	Retransmission output signal source selection 0 : SV1 (Loop1 SV) 1 : PV1 (Loop1 PV) 2 : MV1 (Loop1 main out manipulated value) 3 : SV1R (Loop1 SV reverse) 4 : PV1R (Loop1 PV reverse) 5 : MV1R (Loop1 main out manipulated reverse value) 6 : SV2 (Loop2 SV) 7 : PV2 (Loop2 PV) 8 : MV2 (Loop2 main out manipulated value) 9 : SV2R (Loop2 SV reverse) 10 : PV2R (Loop2 PV reverse) 11 : MV2R (Loop2 main out manipulated reverse value)	12	0	0x10D	269	0x10D	269	R/W	0		

Parameter	Display	Level	Description	Range		Address				R/W	Initial		
				Max	Min	LOOP1		LOOP2					
						Hex	Dec	Hex	Dec				
AO.LO		Level 5	Retransmission output scale low	USPL	LSPL	0x10E	270	0x10E	270	R/W	LSPL		
AO.HI		Level 5	Retransmission output scale high	USPL	LSPL	0x10F	271	0x10F	271	R/W	USPL		
AOCL		Level 5	For retransmission zero calibration	9999	0	0x110	272	0x110	272	R/W	0		
AOCH		Level 5	For retransmission span calibration	9999	0	0x111	273	0x111	273	R/W	3600		
CTRT		Level 5	Reserve	100	1	0x112	274	0x112	274	R/W	1		
D1SL		Level 5	LOOP1 digital input function selection 0 : OFF (disable digital input function) 1 : SWSV (switch 4 sets of SV) 2 : R_S (switch RUN/STOP) 3 : A_M (switch Auto/Manual) 4 : AT (ON/OFF auto-tuning) 5 : RESV (ON/OFF remote SV) 6 : AOEN (ON/OFF retransmission) 7 : TIM (ON/OFF timer) 8 : CNT(counter) 9 : PROG (run/reset program)	99	0	0x113	275	0x113	275	R/W	0		
D2SL		Level 5	LOOP2 digital input function selection 0 : OFF (disable digital input function) 1 : SWSV (switch 4 sets of SV) 2 : R_S (switch RUN/STOP) 3 : A_M (switch Auto/Manual) 4 : AT (ON/OFF auto-tuning) 5 : RESV (ON/OFF remote SV) 6 : AOEN (ON/OFF retransmission) 7 : TIM (ON/OFF timer) 8 : CNT(counter)	99	0	0x114	276	0x114	276	R/W	0		
REMO		Level 5	Program execute via remote control OFF : program execute by key ON : program execute by digital input or communication	1	0	0x115	277	0x115	277	R/W	0		
CJSL		Level 5	Cold junction compensation mode selection 0 : AUTO (auto cold junction compensation) 1 : MAN (manual cold junction compensation)	1	0	0x116	278	0x116	278	R/W	0		
CJMN		Level 5	Manual cold junction temperature setting	500	-100	0x117	279	0x117	279	R/W	25		
CJTC		Level 5	Current cold junction temperature display	---	---	0x118	280	0x118	280	R/W	---		
W_MD		Level 5	EEPROM protection 0 : OFF communication write command only write to CPU RAM 1 : ON communication write command write to CPU RAM and EEPROM	1	0	0x119	281	0x119	281	R	1		
RMAP		Level 5	Register mapping 0 : OFF (disable register mapping) 1 : FY (mapping to FY series memory address) 2 : FE (mapping to FE series memory address) 3 : FA (mapping to FA series memory address)	5	0	0x11A	282	0x11A	282	R/W	0		

7. Communication Data List

Parameter	Display	Level	Description	Range		Address				R/W	Initial		
				Max	Min	LOOP1		LOOP2					
						Hex	Dec	Hex	Dec				
OPSL		Level 5	Loop hardware distribution 0 : LOP1 loop1 main out drive out1 hardware, sub out drive out2 hardware (use for dual output) 1 : LOP2 loop2 main out drive out1 hardware, sub out drive out2 hardware (use for dual output) 2 : LP12 loop1 main out drive out1 hardware, loop2 main out drive out2 hardware (use for single output)	2	0	0x11B	283	0x11B	283	R/W	2		
POTM		Level 5	System steady state time output and alarm function will enable after waiting for this setting value when power-on	99.59	6	0x11C	284	0x11C	284	R/W	6		
PTMD		Level 5	Program time format 0 : SEC (minute.second) 1 : MIN (hour.minute) 2 : 50MS (50ms)	2	0	0x11D	285	0x11D	285	R/W	0		
PVST		Level 5	Program execute start address 0 : ZERO (execute from zero) 1 : FULT (execute from current PV, but use segment 1 fully time) 2 : CUTT (execute from current PV, cut time)	2	0	0x11E	286	0x11E	286	R/W	1		
REPT		Level 5	Program execute repeat 0 : OFF (disable repeat function) Other : Program execute repeat number of times	9999	0	0x11F	287	0x11F	287	R/W	0		
POWF		Level 5	Program execute power fail protection 0 : OFF (disable power fail protection) 1 : ON (enable power fail protection)	1	0	0x120	288	0x120	288	R/W	0		
D01		Level 5	Reserve	32767	-32768	0x121	289	0x121	289	R/W	0		
D02		Level 5	Reserve	32767	-32768	0x122	290	0x122	290	R/W	0		
D03		Level 5	Reserve	32767	-32768	0x123	291	0x123	291	R/W	0		
D04		Level 5	Reserve	32767	-32768	0x124	292	0x124	292	R/W	0		
D05		Level 5	Reserve	32767	-32768	0x125	293	0x125	293	R/W	0		
D06		Level 5	Reserve	32767	-32768	0x126	294	0x126	294	R/W	0		
D07		Level 5	Reserve	32767	-32768	0x127	295	0x127	295	R/W	0		
D08		Level 5	Reserve	32767	-32768	0x128	296	0x128	296	R/W	0		
D09		Level 5	Reserve	32767	-32768	0x129	297	0x129	297	R/W	0		
D10		Level 5	Reserve	32767	-32768	0x12A	298	0x12A	298	R/W	0		
D11		Level 5	Reserve	32767	-32768	0x12B	299	0x12B	299	R/W	0		
D12		Level 5	Reserve	32767	-32768	0x12C	300	0x12C	300	R/W	0		
D13		Level 5	Reserve	32767	-32768	0x12D	301	0x12D	301	R/W	0		
D14		Level 5	Reserve	32767	-32768	0x12E	302	0x12E	302	R/W	0		
D15		Level 5	Reserve	32767	-32768	0x12F	303	0x12F	303	R/W	0		
D16		Level 5	Reserve	32767	-32768	0x130	304	0x130	304	R/W	0		

Parameter	Display	Level	Description	Range		Address				R/W	Initial		
				Max	Min	LOOP1		LOOP2					
						Hex	Dec	Hex	Dec				
D17	8017	Level 5	Reserve	32767	-32768	0x131	305	0x131	305	R/W	0		
D18	8018	Level 5	Reserve	32767	-32768	0x132	306	0x132	306	R/W	0		
D19	8019	Level 5	Reserve	32767	-32768	0x133	307	0x133	307	R/W	0		
D20	8077	Level 5	Reserve	32767	-32768	0x134	308	0x134	308	R/W	0		
MPW	---	---	Verification code	9999	0	0x3FE	1022	0x3FE	1022	R/W	0		
MSG1	---	---	LOOP1 error message indictor bit 2 ⁰ = INER 2 ¹ = UUUU 2 ² = NNNN 2 ³ = AUTF 2 ⁴ = r 2 ⁵ = r 2 ⁶ = r 2 ⁷ = r 2 ⁸ = CJER 2 ⁹ = CJOR 2 ¹⁰ = CJNR 2 ¹¹ = ADCF 2 ¹² = RAMF 2 ¹³ = r 2 ¹⁴ = r 2 ¹⁵ = r ※ r : reserve	65535	0	0x407	1031	0x407	1031	R	---		
LAP1	---	---	LOOP1 led message indictor bit 2 ⁰ = OUT1 2 ¹ = OUT2 2 ² = AT 2 ³ = AL1 2 ⁴ = AL2 2 ⁵ = AL3 2 ⁶ = COM 2 ⁷ = MAN 2 ⁸ = Program_Run 2 ⁹ = Program_End 2 ¹⁰ = Program_Wait 2 ¹¹ = r 2 ¹² = Program_Halt 2 ¹³ = r 2 ¹⁴ = r 2 ¹⁵ = r ※ r : reserve	65535	0	0x408	1032	0x408	1032	R	---		
PKE1	---	---	LOOP1 program remote control 2 ⁰ = r 2 ¹ = r 2 ² = r 2 ³ = r 2 ⁴ = r 2 ⁵ = r 2 ⁶ = r 2 ⁷ = r 2 ⁸ = 256 (RUN) 2 ⁹ = 512 (HALT) 2 ¹⁰ = 1024 (JUMP) 2 ¹¹ = 2048 (RESET) 2 ¹² = r 2 ¹³ = r 2 ¹⁴ = r 2 ¹⁵ = r ※ r : reserve	65535	0	0x409	1033	0x409	1033	R/W	---		

7. Communication Data List

Parameter	Display	Level	Description	Range		Address				R/W	Initial		
				Max	Min	LOOP1		LOOP2					
						Hex	Dec	Hex	Dec				
MSG2	---	---	LOOP2 error message indictor bit 2 ⁰ = INER 2 ¹ = UUUU 2 ² = NNNN 2 ³ = AUTF 2 ⁴ = r 2 ⁵ = r 2 ⁶ = r 2 ⁷ = r 2 ⁸ = CJER 2 ⁹ = CJOR 2 ¹⁰ = CNJR 2 ¹¹ = ADCF 2 ¹² = RAMF 2 ¹³ = r 2 ¹⁴ = r 2 ¹⁵ = r ※ r : reserve	65535	0	0x40A	1034	0x40A	1034	R	---		
LAP2	---	---	LOOP2 led message indictor bit 2 ⁰ = OUT1 2 ¹ = OUT2 2 ² = AT 2 ³ = AL1 2 ⁴ = AL2 2 ⁵ = AL3 2 ⁶ = COM 2 ⁷ = MAN 2 ⁸ = r 2 ⁹ = r 2 ¹⁰ = r 2 ¹¹ = r 2 ¹² = r 2 ¹³ = r 2 ¹⁴ = r 2 ¹⁵ = r ※ r : reserve	65535	0	0x40B	1035	0x40C	1035	R	---		
PKE2	---	---	LOOP2 program remote control 2 ⁰ = r 2 ¹ = r 2 ² = r 2 ³ = r 2 ⁴ = r 2 ⁵ = r 2 ⁶ = r 2 ⁷ = r 2 ⁸ = 256 (RUN) 2 ⁹ = 512 (HALT) 2 ¹⁰ = 1024 (JUMP) 2 ¹¹ = 2048 (RESET) 2 ¹² = r 2 ¹³ = r 2 ¹⁴ = r 2 ¹⁵ = r ※ r : reserve	65535	0	0x40C	1036	0x40C	1036	R/W	---		
FEDI	---	---	Firmware edition	32767	-32767	0x40E	1038	0x40E	1038	R	---		
1P10	---	---	LOOP1_PV x 10	32767	-32767	0x40F	1039	0x40F	1039	R	---		
2P10	---	---	LOOP2_PV x 10	32767	-32767	0x410	1040	0x410	1040	R	---		
1MMV	---	---	LOOP1 main out manipulated value	1000	0	0x411	1041	0x411	1041	R	---		
1SMV	---	---	LOOP1 sub out manipulated value	1000	0	0x412	1042	0x412	1042	R	---		
2MMV	---	---	LOOP2 main out manipulated value	1000	0	0x413	1043	0x413	1043	R	---		
2SMV	---	---	LOOP2 sub out manipulated value	1000	0	0x414	1044	0x414	1044	R	---		

7.2 Piece Linear Compensation Parameters Address

Linearize number	Parameter	Address	
		Hex	Dec
MLNB = 1	COMP	0x15B	347
	OFFS	0x165	357
MLNB = 2	COMP	0x15C	348
	OFFS	0x166	358
MLNB = 3	COMP	0x15D	349
	OFFS	0x167	359
MLNB = 4	COMP	0x15E	350
	OFFS	0x168	360
MLNB = 5	COMP	0x15F	351
	OFFS	0x169	361
MLNB = 6	COMP	0x160	352
	OFFS	0x16A	362
MLNB = 7	COMP	0x161	353
	OFFS	0x16B	363
MLNB = 8	COMP	0x162	354
	OFFS	0x16C	364
MLNB = 9	COMP	0x163	355
	OFFS	0x16D	365
MLNB = 10	COMP	0x164	356
	OFFS	0x16E	366

7.3 All Model Parameters Address

7.3.1 RMAP = OFF

Parameter	Address		R / W
	Hex	Dec	
PV	0x00	0	R
SV	0x01	1	R / W
LOOP	0x02	2	R / W
R_S	0x03	3	R / W
HBCU	0x04	4	R
HBSV	0x05	5	R / W
HTBM	0x06	6	R / W
AL1H	0x07	7	R / W
AL1L	0x08	8	R / W
AL2H	0x09	9	R / W
AL2L	0x0A	10	R / W
AL3H	0x0B	11	R / W
AL3L	0x0C	12	R / W
SV1	0x0D	13	R / W
SV2	0x0E	14	R / W
SV3	0x0F	15	R / W
SV4	0x10	16	R / W
TIM	0x11	17	R / W
CNT	0x12	18	R / W
CUTM	0x13	19	R / W
ONTM	0x14	20	R / W
OFTM	0x15	21	R / W
A_M	0x16	22	R / W
MOUT	0x17	23	R / W
AT	0x18	24	R / W
RATE	0x19	25	R / W
RAMP	0x1A	26	R / W
SOAK	0x1B	27	R / W
WAIT	0x1C	28	R / W
DTM1	0x1D	29	R / W
DTM2	0x1E	30	R / W
DTM3	0x1F	31	R / W
DTM4	0x20	32	R / W
DT_ST	0x21	33	R / W
PTN	0x22	34	R / W
SEG	0x23	35	R
L1SV	0x24	36	R
L2SV	0x25	37	R
TIMR	0x26	38	R
DOUT	0x27	39	R / W
P1	0x28	40	R / W
I1	0x2A	42	R / W
D1	0x2C	44	R / W
HYS1	0x2E	46	R / W
CYT1	0x2F	47	R / W
MOLH	0x30	48	R / W
MOLL	0x31	49	R / W
P2	0x32	50	R / W

Parameter	Address		R / W
	Hex	Dec	
I2	0x34	52	R / W
D2	0x36	54	R / W
HYS2	0x38	56	R / W
CYT2	0x39	57	R / W
SOLH	0x3A	58	R / W
SOLL	0x3B	59	R / W
MGAP	0x3C	60	R / W
SGAP	0x3D	61	R / W
COUT	0x3E	62	R
AT.VL	0x3F	63	R / W
SS.PO	0x40	64	R / W
OPSF	0x41	65	R / W
RC_TO	0x42	66	R / W
LOCK	0x43	67	R / W
INPT	0x44	68	R / W
AN.LO	0x45	69	R / W
AN.HI	0x46	70	R / W
DP	0x47	71	R / W
HI.RA	0x48	72	R / W
LO.RA	0x49	73	R / W
USPL	0x4A	74	R / W
LSPL	0x4B	75	R / W
ALD1	0x4C	76	R / W
ALT1	0x4D	77	R / W
HYA1	0x4E	78	R / W
SEA1	0x4F	79	R / W
ALD2	0x50	80	R / W
ALT2	0x51	81	R / W
HYA2	0x52	82	R / W
SEA2	0x53	83	R / W
ALD3	0x54	84	R / W
ALT3	0x55	85	R / W
HYA3	0x56	86	R / W
SEA3	0x57	87	R / W
MOCL	0x58	88	R / W
MOCH	0x59	89	R / W
SOCL	0x5A	90	R / W
SOCH	0x5B	91	R / W
MV.SF	0x5C	92	R / W
RC.TI	0x5D	93	R / W
UNIT	0x5E	94	R / W
OUTM	0x5F	95	R / W
SV.OS	0x60	96	R / W
PV.OS	0x61	97	R / W
PV.OH	0x62	98	R / W
MLNB	0x63	99	R / W
COMP	0x64	100	R / W
OFFS	0x65	101	R / W

7.3.1 RMAP = OFF

Parameter	Address		R / W
	Hex	Dec	
SV.TY	0x66	102	R / W
OU.TY	0x67	103	R / W
PMAC	0x68	104	R / W
FKSL	0x69	105	R / W
BIAS	0x6A	106	R / W
TP_K	0x6B	107	R / W
TMSL	0x6C	108	R / W
MVRT	0x6D	109	R / W
HYSM	0x6E	110	R / W
RH.TC	0x6F	111	R / W
RH.PO	0x70	112	R / W
RH.TM	0x71	113	R / W
PR.SV	0x72	114	R / W
HBOP	0x73	115	R / W
SET1	0x74	116	R / W
SET2	0x75	117	R / W
SET3	0x76	118	R / W
SET4	0x77	119	R / W
SET5	0x78	120	R / W
SET6	0x79	121	R / W
SET7	0x7A	122	R / W
SET8	0x7B	123	R / W
SET9	0x7C	124	R / W
SETA	0x7D	125	R / W
SETB	0x7E	126	R / W
SETC	0x7F	127	R / W
SETD	0x80	128	R / W
SETE	0x81	129	R / W
SETF	0x82	130	R / W
HZ	0x106	262	R / W
PRTO	0x107	263	R
FOMA	0x108	264	R
IDNO	0x109	265	R
BAUD	0x10A	266	R
RPDT	0x10B	267	R / W
AOEN	0x10C	268	R / W
AOSL	0x10D	269	R / W
AO.LO	0x10E	270	R / W
AO.HI	0x10F	271	R / W

Parameter	Address		R / W
	Hex	Dec	
AOCL	0x110	272	R / W
AOCH	0x111	273	R / W
CTRT	0x112	274	R / W
D1SL	0x113	275	R / W
D2SL	0x114	276	R / W
REMO	0x115	277	R / W
CJSL	0x116	278	R / W
CJMN	0x117	279	R / W
CJTC	0x118	280	R / W
W_MD	0x119	281	R
RMAP	0x11A	282	R / W
OPSL	0x11B	283	R / W
POTM	0x11C	284	R / W
PTMD	0x11D	285	R / W
PVST	0x11E	286	R / W
REPT	0x11F	287	R / W
POWF	0x120	288	R / W
D01	0x121	289	R / W
D02	0x122	290	R / W
D03	0x123	291	R / W
D04	0x124	292	R / W
D05	0x125	293	R / W
D06	0x126	294	R / W
D07	0x127	295	R / W
D08	0x128	296	R / W
D09	0x129	297	R / W
D10	0x12A	298	R / W
D11	0x12B	299	R / W
D12	0x12C	300	R / W
D13	0x12D	301	R / W
D14	0x12E	302	R / W
D15	0x12F	303	R / W
D16	0x130	304	R / W
D17	0x131	305	R / W
D18	0x132	306	R / W
D19	0x133	307	R / W
D20	0x134	308	R / W

7.3.2 RMAP = FY

Parameter	Address		R / W
	Hex	Dec	
SV	0x00	0	R / W
OUTL	0x01	1	R / W
AT	0x02	2	R / W
AL1	0x03	3	R / W
SOAK			
HBAC			
AL2	0x04	4	R / W
SOAK			
HBAC			
AL3	0x05	5	R / W
SOAK			
RAMP			
RATE			
PTN	0x06	6	R
SEG	0x07	7	R
TIMR	0x08	8	R
SV_1	0x09	9	R / W
TM_1	0x0A	10	R / W
OUT1	0x0B	11	R / W
SV_2	0x0C	12	R / W
TM_2	0x0D	13	R / W
OUT2	0x0E	14	R / W
SV_3	0x0F	15	R / W
TM_3	0x10	16	R / W
OUT3	0x11	17	R / W
SV_4	0x12	18	R / W
TM_4	0x13	19	R / W
OUT4	0x14	20	R / W
SV_5	0x15	21	R / W
TM_5	0x16	22	R / W
OUT5	0x17	23	R / W
SV_6	0x18	24	R / W
TM_6	0x19	25	R / W
OUT6	0x1A	26	R / W
SV_7	0x1B	27	R / W
TM_7	0x1C	28	R / W
OUT7	0x1D	29	R / W
SV_8	0x1E	30	R / W
TM_8	0x1F	31	R / W
OUT8	0x20	32	R / W
SV_12	0x21	33	R / W
TM_12	0x22	34	R / W
OUT12	0x23	35	R / W
SV_22	0x24	36	R / W
TM_22	0x25	37	R / W
OUT22	0x26	38	R / W
SV_32	0x27	39	R / W
TM_32	0x28	40	R / W
OUT32	0x29	41	R / W
SV_42	0x2A	42	R / W
TM_42	0x2B	43	R / W
OUT42	0x2C	44	R / W
SV_52	0x2D	45	R / W
TM_52	0x2E	46	R / W
OUT52	0x2F	47	R / W
SV_62	0x30	48	R / W
TM_62	0x31	49	R / W
OUT62	0x32	50	R / W
SV_72	0x33	51	R / W
TM_72	0x34	52	R / W
OUT72	0x35	53	R / W
SV_82	0x36	54	R / W

Parameter	Address		R / W
	Hex	Dec	
TM_82	0x37	55	R / W
OUT82	0x38	56	R / W
P1	0x39	57	R / W
I1	0x3A	58	R / W
D1	0x3B	59	R / W
AT.VL	0x3D	61	R / W
CYT1	0x3E	62	R / W
HYS1	0x3F	63	R / W
P2	0x40	64	R / W
I2	0x41	65	R / W
D2	0x42	66	R / W
CYT2	0x43	67	R / W
HYS2	0x44	68	R / W
GAP1	0x45	69	R / W
GAP2	0x46	70	R / W
LCK	0x47	71	R / W
INP1	0x48	72	R / W
ANL1	0x49	73	R / W
ANH1	0x4A	74	R / W
DP	0x4B	75	R / W
LSPL	0x4C	76	R / W
USPL	0x4D	77	R / W
ANL2	0x4E	78	R / W
ANH2	0x4F	79	R / W
ALD1	0x50	80	R / W
ALT1	0x51	81	R / W
ALD2	0x52	82	R / W
ALT2	0x53	83	R / W
ALD3	0x54	84	R / W
ALT3	0x55	85	R / W
HYSA	0x56	86	R / W
CLO1	0x57	87	R / W
CHO1	0x58	88	R / W
CLO2	0x59	89	R / W
CHO2	0x5A	90	R / W
CLO3	0x5B	91	R / W
CHO3	0x5C	92	R / W
RUCY	0x5D	93	R / W
WAIT	0x5E	94	R / W
SETA	0x5F	95	R / W
PSL	0x60	96	R
BITS	0x61	97	R
IDNO	0x62	98	R
BAUD	0x63	99	R
SVOS	0x64	100	R / W
PVOS	0x65	101	R / W
UNIT	0x66	102	R / W
PVFT	0x67	103	R / W
PV2	0x68	104	R / W
OUD	0x69	105	R / W
OPAD	0x6A	106	R / W
HZ	0x6B	107	R / W
SET1	0x6C	108	R / W
SET2	0x6D	109	R / W
SET3	0x6E	110	R / W
SET4	0x6F	111	R / W
SET5	0x70	112	R / W
SET6	0x71	113	R / W
SET7	0x72	114	R / W
SET8	0x73	115	R / W
SET9	0x74	116	R / W
SET0	0x75	117	R / W

7.3.2 RMAP = FY

Address	Address		R / W
	Hex	Dec	
INP2	0x76	118	R / W
OUTY	0x77	119	R / W
OUT%	0x87	135	R
OBIT	0x88	136	R
CV	0x89	137	R
PV	0x8A	138	R
HBOP	0x12C	300	R / W
OPFT	0x12D	301	R / W

Address	Address		R / W
	Hex	Dec	
MOLL	0x12E	302	R / W
RH.TC	0x12F	303	R / W
RH.PO	0x130	304	R / W
RH.TM	0x131	305	R / W
MOLH	0x01	1	R / W
HYSM	0x44	68	R / W
TRCL	0x132	306	R / W
TRCH	0x133	307	R / W

7.3.3 RMAP = FE

Old FE Address

Parameter	Address		R / W
	Hex	Dec	
SV	0x00	0	R / W
PV	0x01	1	R
SV2	0x02	2	R / W
PV2	0x03	3	R
HBAC	0x04	4	R / W
HBAT	0x05	5	R / W
R-S	0x06	6	R / W
OLH1	0x07	7	R / W
OLL1	0x08	8	R / W
OLH2	0x09	9	R / W
OLL2	0x0A	10	R / W
AT	0x0B	11	R / W
AL1H	0x0C	12	R / W
AL1L	0x0D	13	R / W
AL2H	0x0E	14	R / W
AL2L	0x0F	15	R / W
AL3H	0x10	16	R / W
AL3L	0x11	17	R / W
SV_1	0x12	18	R / W
SV_2	0x13	19	R / W
SV_3	0x14	20	R / W
A-M	0x15	21	R / W
MOP	0x16	22	R / W
P1	0x35	53	R / W
I1	0x36	54	R / W
D1	0x37	55	R / W
CYT1	0x38	56	R / W
SOF1	0x39	57	R / W
HYO1	0x3A	58	R / W
OP1	0x3B	59	R
P2	0x3C	60	R / W
I2	0x3D	61	R / W
D2	0x3E	62	R / W
CYT2	0x3F	63	R / W
SOF2	0x40	64	R / W
GAP.1	0x41	65	R / W
GAP.2	0x42	66	R / W
HYO2	0x43	67	R / W
OP2	0x44	68	R
ATVL	0x45	69	R / W
LCK	0x4B	75	R / W
INP1	0x4C	76	R / W
ANL1	0x4D	77	R / W
ANH1	0x4E	78	R / W
DP	0x4F	79	R / W
LSPL	0x50	80	R / W
USPL	0x51	81	R / W
SVL1	0x52	82	R / W
SVH1	0x53	83	R / W
PLL1	0x54	84	R / W
PHH1	0x55	85	R / W
ALD1	0x56	86	R / W
ALT1	0x57	87	R / W
HYS1	0x58	88	R / W
ALD2	0x59	89	R / W
ALT2	0x5A	90	R / W
HYS2	0x5B	91	R / W
ALD3	0x5C	92	R / W
ALT3	0x5D	93	R / W
HYS3	0x5E	94	R / W
SETA	0x5F	95	R / W

Parameter	Address		R / W
	Hex	Dec	
CLO1	0x60	96	R / W
CHO1	0x61	97	R / W
CLO2	0x62	98	R / W
CHO2	0x63	99	R / W
TE	0x64	100	R / W
TS	0x65	101	R / W
TSPL	0x66	102	R / W
TSPH	0x67	103	R / W
CLO3	0x68	104	R / W
CHO3	0x69	105	R / W
RUCY	0x6A	106	R / W
WAIT	0x6B	107	R / W
PSL	0x6C	108	R / W
BITS	0x6D	109	R / W
IDNO	0x6E	110	R / W
BAUD	0x6F	111	R / W
INT	0x70	112	R / W
SVOS	0x71	113	R / W
PVOS	0x72	114	R / W
PVOH	0x73	115	R / W
PVFT	0x74	116	R / W
UNIT	0x75	117	R / W
OUD	0x76	118	R / W
HZ	0x77	119	R / W
INP2	0x78	120	R / W
ANL2	0x79	121	R / W
ANH2	0x7A	122	R / W
DP_2	0x7B	123	R / W
LSP2	0x7C	124	R / W
USP2	0x7D	125	R / W
SVL2	0x7E	126	R / W
SVH2	0x7F	127	R / W
PLL2	0x80	128	R / W
PHH2	0x81	129	R / W
SVO2	0x82	130	R / W
PVS2	0x83	131	R / W
PVH2	0x84	132	R / W
PVF2	0x85	133	R / W
UNI2	0x86	134	R / W
FKSL	0x87	135	R / W
DIE	0x8C	140	R / W
DIS	0x8D	141	R / W
SET1	0x8E	142	R / W
SET2	0x8F	143	R / W
SET3	0x90	144	R / W
SET4	0x91	145	R / W
SET5	0x92	146	R / W
SET6	0x93	147	R / W
SET7	0x94	148	R / W
SET8	0x95	149	R / W
SET9	0x96	150	R / W
SET0	0x97	151	R / W
OUTY	0x9D	157	R / W
R-M	0x9E	158	R / W
CJS	0x9F	159	R / W
CJM	0xA0	160	R / W
CJT	0xA1	161	R
OBIT	0xA2	162	R

7.3.3 RMAP = FE

Old FE Address

Parameter	Address		R / W
	Hex	Dec	
D_01	0xA5	165	R / W
D_02	0xA6	166	R / W
D_03	0xA7	167	R / W
D_04	0xA8	168	R / W
D_05	0xA9	169	R / W
D_06	0xAA	170	R / W
D_07	0xAB	171	R / W

Parameter	Address		R / W
	Hex	Dec	
D_09	0xAD	173	R / W
D_10	0xAE	174	R / W
D_11	0xAF	175	R / W
D_12	0xB0	176	R / W
D_13	0xB1	177	R / W
D_14	0xB2	178	R / W
D_15	0xB3	179	R / W

MEMO

MEMO



2022.12.20



台灣儀控股份有限公司
TAIWAN INSTRUMENT & CONTROL CO., LTD

Phone: +886-2-8226-1867 E-mail:contact@fa-taie.com.tw
Fax: +886-2-8226-1834 URL:<http://www.fa-taie.com.tw>